


NOTES:-

1. ALL UNDERGROUND ELECTRICAL SERVICE CONNECTIONS SHALL BE LAID IN ACCORDANCE WITH REQUIREMENTS OF ETSA UTILITIES AND THE AUSTRALIAN STANDARD SPECIFICATION AS 3000 PART 1 1976 (SAA WIRING RULES).
2. THE UNDER GROUND ELECTRICAL CONNECTION TO A PROPERTY SHALL ONLY BE UNDERTAKEN BY A SUITABLY QUALIFIED LICENSED CONTRACTOR.
3. TRENCHING AND BACKFILL SHALL BE DONE IN ACCORDANCE WITH THE CITY OF SALISBURY STANDARD DETAIL SHEET SD-33.
4. FOOTPATH PAVEMENTS SHALL BE REINSTATED IN ACCORDANCE WITH THE CITY OF SALISBURY STANDARD DETAIL SD-32,SD-37 AND SD-38.
5. ALL DISTURBED VERGE AREAS SHALL BE REINSTATED WITH "LIKE" MATERIAL.
6. REFER UNDERGROUND ELECTRICAL SERVICE CONNECTION.
7. SEWER CONNECTION TO BE MINIMUM OF 300mm FROM ELECTRICAL CONNECTION IN ACCORDANCE WITH AS3500.1:2003.



STANDARD DETAIL
UNDERGROUND ELECTRICAL SERVICE
INSTALLATION

PLAN No.

SD-40

APPROVED.....C.HASKAS...
Manager Civil Design

DATE.....11/4/07..

DRAWN/DESIGNED

N.SCOTT

CHECKED

A.S. TAYLOR

CAD FILE NAME

SD-40.dwg

SHEET SIZE

A4

REVISION

0